



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx SIR 12.0070X

Issue No: 8

Certificate history:

Status: **Current**

Issue No. 8 (2019-03-04)

Issue No. 7 (2018-07-18)

Date of Issue: **2019-03-04**

Page 1 of 4

Issue No. 6 (2018-03-08)

Issue No. 5 (2017-09-06)

Applicant: **Wolf Safety Lamp Company Limited**  
Saxon Road Works  
Sheffield S8 0YA  
United Kingdom

Issue No. 4 (2016-09-01)

Issue No. 3 (2016-04-21)

Issue No. 2 (2015-12-15)

Issue No. 1 (2012-12-06)

Issue No. 0 (2012-06-19)

Equipment: **LX-XXX LinkEx LED Luminaires**

*Optional accessory:*

Type of Protection: **Increased Safety, Encapsulation and Dust Protection by Enclosure**

Marking:

Refer to the certificate Annexe for the marking

*Approved for issue on behalf of the IECEx  
Certification Body:*

N Jones

*Position:*

Certification Manager

*Signature:  
(for printed version)*

*Date:*

*N. Jones*  
\_\_\_\_\_  
*2019-03-04*

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**SIRA Certification Service**  
CSA Group  
Unit 6, Hawarden Industrial Park  
Hawarden, Deeside, CH5 3US  
United Kingdom

**sira**  
CERTIFICATION





# IECEX Certificate of Conformity

Certificate No: IECEX SIR 12.0070X Issue No: 8  
Date of Issue: **2019-03-04** Page 2 of 4  
Manufacturer: **Wolf Safety Lamp Company Limited**  
Saxon Road Works  
Sheffield S8 0YA  
United Kingdom

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended.

## STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2011</b> Edition:6.0	Explosive atmospheres - Part 0: General requirements
<b>IEC 60079-18 : 2014</b> Edition:4.0	Explosive atmospheres – Part 18: Equipment protection by encapsulation "m"
<b>IEC 60079-28 : 2015</b> Edition:2	Explosive atmospheres - Part 28: Protection of equipment and transmission systems using optical radiation
<b>IEC 60079-31 : 2013</b> Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
<b>IEC 60079-7 : 2015</b> Edition:5.0	Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

### Test Report:

GB/SIR/ExTR12.0134/00	GB/SIR/ExTR12.0278/00	GB/SIR/ExTR15.0329/00
GB/SIR/ExTR16.0019/00	GB/SIR/ExTR16.0220/00	GB/SIR/ExTR17.0170/00
GB/SIR/ExTR18.0025/00	GB/SIR/ExTR18.0116/00	GB/SIR/ExTR19.0047/00

### Quality Assessment Report:

GB/BAS/QAR06.0017/08



# IECEx Certificate of Conformity

Certificate No: IECEx SIR 12.0070X

Issue No: 8

Date of Issue: 2019-03-04

Page 3 of 4

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

The LX-XXX LinkEx LED Luminaires are suitable for temporary lighting installations and are fully described in the Annexe to this certificate.

### SPECIFIC CONDITIONS OF USE: YES as shown below:

1. The user/installer shall ensure that, when the luminaire is fitted with a previously certified plug or socket that has associated specific conditions of use, they shall take into account any restrictions or conditions for safe use that are applicable to these devices
2. Some of the Sockets used in this equipment may bear intrinsically safe marking, this safety concept is not relevant to the construction of the luminaires covered by this certificate, however, these luminaires do rely on the other concepts, flameproof and increased safety, that are applied to these certified Sockets. The user shall therefore take this into consideration when installing this equipment and the luminaires shall not be involved with any intrinsically safe circuitry.



# IECEX Certificate of Conformity

Certificate No: IECEx SIR 12.0070X

Issue No: 8

Date of Issue: 2019-03-04

Page 4 of 4

**DETAILS OF CERTIFICATE CHANGES (for Issues 1 and above):**

Refer to Annexe

**Annex:**


[IECEX SIR 12.0070X Issue 8 Annexe.pdf](#)

**Annexe to:** IECEx SIR 12.0070X Issue 8  
**Applicant:** Wolf Safety Lamp Company Limited  
**Apparatus:** LX-XXX LinkEx LED Luminaires



## Marking

### Luminaires fitted with Mk1 Drivers

 II 2GD  
Ex eb mb op is IIC T3 Gb  
Ex tb op is IIIC T170°C Db IP6X


### Luminaires fitted with Mk2 Drivers

 II 2GD  
Ex eb mb op is IIC T4 Gb  
Ex tb op is IIIC T135°C Db IP 6X

Ta = -20°C to +55°C  
Ta = -20°C to +45°C with protective cover fitted

**Luminaires that are fitted with either Stahl Type 8575 or Stahl Type 8591 Sockets are not dust approved as detailed below:**

### Luminaires fitted with Mk1 Drivers

 II 2G  
Ex eb mb op is IIC T3 Gb

### Luminaires fitted with Mk2 Drivers

 II 2G  
Ex eb mb op is IIC T4 Gb  
Ta = -20°C to +55°C  
Ta = -20°C to +45°C with protective cover fitted

## LX-XXXE Luminaire Marking

Ex eb mb op is IIC T4 Gb  
Ex tb op is IIIC T135°C Db IP 6X Ta = -20°C to +55°C  
Ta = -20°C to +45°C with protective cover fitted

**Luminaires that are fitted with either Stahl Type 8575 or Stahl Type 8591 Sockets are not dust approved as described below**

Ex eb mb op is IIC T4 Gb Ta = -20°C to +55°C  
Ta = -20°C to +45°C with protective cover fitted

## Equipment

The LX-XXX LinkEx LED Luminaires are suitable for temporary lighting installations. The luminaires comprise a clear, tubular, polycarbonate lamp envelope with two polycarbonate end mouldings. The lamp envelope is all treated with a clear anti static coating to safely dissipate any static electricity. The end mouldings are secured to the tube via the internal gear tray, which is fabricated from steel or aluminium, two M5 and two M6 screws and bonded seals are used to secure each end cap. A silicone gasket is fitted within a groove on each end cap, thus maintaining the IP54/IP64 (as applicable) ratings. The luminaires have additionally been independently tested according to the requirements of EN/IEC 60529 to meet IP 67, with no sockets fitted, IP 66 when sockets are fitted and IP54 for Stahl Type 8575 or 8591 sockets.

The luminaires' are fitted with replaceable bump ring clamped between the seal ring and end plate, giving additional protection to the luminaire.

180° variant – These comprise a main gear tray, with the driver and terminal connection blocks on the underside with two LED strips fitted to the upper, distributing the light through 180°.

360° variant – These comprise two gear trays and two narrow channels, with the driver and terminal connection blocks fitted along with two LED strips, one fitted to each side, distributing the light through 360°.

The following optional supply terminal blocks may be fitted:

**Date:** 04 March 2019

Page 1 of 4

**Form 9530 Issue 1**

## Sira Certification Service

Unit 6 Hawarden Industrial Park,  
Hawarden, CH5 3US, United Kingdom

Tel: +44 (0) 1244 670900  
Fax: +44 (0) 1244 681330  
Email: [ukinfo@csagroup.org](mailto:ukinfo@csagroup.org)  
Web: [www.csagroupuk.org](http://www.csagroupuk.org)

**Annexe to:** IECEx SIR 12.0070X Issue 8

**Applicant:** Wolf Safety Lamp Company Limited

**Apparatus:** LX-XXX LinkEx LED Luminaires



Manufacturer	Type Ref.	Coded	Certificate no.
Weidmüller	Type BK	Ex e II	IECEX SIR 05.0035U
Weidmüller	Type MK6	Ex e II	IECEX SIR 05.0037U
Phoenix Contact GmbH & Co. KG	Type G5/..-EX	Ex e II	IECEX PTB 06.0043U

Luminaires can be supplied with sockets fitted to the end caps with bolts, nuts and sealing washers and/or various lengths of cable with plugs fitted. The following optional certified sockets may be fitted to the linkable versions only:

Manufacturer	Type Ref.	Coded	Certificate Number
Cooper Crouse-Hinds GmbH	Type GHG 51. ....R....	Ex ed [ia] IIC T6 or T5 Ex tD A21 IP66 T80°C	IECEX BKI 04.0002
R. Stahl	Type 8591/...-..-....	Ex de IIC T6 Ex tD A21 IP66 T52°C	IECEX BKI 07.0001
ATX	Type PCX	Ex de IIC T6 or T5 Ex tD A21 IP66 T68°C	LCIE 02 ATEX 0001U
Marechal	Type DXN1	Ex de IIC T* Ex tD A21 IP66/67 T*	IECEX LCI 09.0005X
Stahl	Type 8570	Ex de IIC T6 Ex tD A21 IP 66 T80°C	IECEX PTB 05.0023

The luminaires when fitted with MK1 drivers are designed for use with an electrical supply of either 85 Vac to 264 Vac, 50/60 Hz or 19 Vdc/ac, rms to 28 Vdc/ac, rms.

The luminaires when fitted with MKII drivers are designed for use with an electrical supply of either 0 Vac to 264 Vac 50/60 Hz or 0 V to 50 V ac/dc, 50/60 Hz

The luminaires may be mounted in any attitude and are suitable for use with accessories.

### Conditions Of Manufacture

- i. The following routine tests shall be performed on each product manufactured:
  - The encapsulated parts of the apparatus shall be subjected to a visual inspection. No visible damage of the compound shall be evident, such as cracks, exposure of the encapsulated parts, flaking, impermissible shrinkage, discoloration, swelling decomposition or softening, as required by IEC 60079-18:2015 Clause 9.1.
  - For equipment rated in excess of 90 V peak, an electric strength test of  $2U+1000$  V (where U is the supply voltage) with a minimum of 1500 V ac, shall be applied between circuit and casing for at least 1 minute, as required by EN 60079-7:2015, Clause 6.1. No breakdown shall occur.
  - For equipment rated less than 90 V peak, and electric strength test of 500 V r.m.s. shall be applied between the circuit and the casing for at least 1 minute, as required by EN 60079-7:2015, Clause 6.1. No breakdown shall occur.

Alternatively a test at 1.2 times the test voltage may be applied for at least 100 ms.

The test is also permitted to be conducted at a dc voltage of 140% of the specified ac r.m.s. test voltage.

- ii. The products covered by this certificate incorporate previously certified devices, it is therefore the responsibility of the manufacturer to continually monitor the status of the certification associated with these devices, and the manufacturer shall inform Sira of any modifications of the devices that may impinge upon the explosion safety design of their products.
- iii. When the luminaire is fitted with a socket that has associated special conditions for safe use, the manufacturer shall take all reasonable steps to ensure that the user/installer complies with these conditions.
- iv. The manufacturer shall select suitable materials for accessories as defined on certified drawings LX-702 & LX-703.

**Date:** 04 March 2019

Page 2 of 4

### Sira Certification Service

Unit 6 Hawarden Industrial Park,  
Hawarden, CH5 3US, United Kingdom

Tel: +44 (0) 1244 670900

Fax: +44 (0) 1244 681330

Email: [ukinfo@csagroup.org](mailto:ukinfo@csagroup.org)

Web: [www.csagroupuk.org](http://www.csagroupuk.org)

**Annexe to:** IECEx SIR 12.0070X Issue 8  
**Applicant:** Wolf Safety Lamp Company Limited  
**Apparatus:** LX-XXX LinkEx LED Luminaires



## Details Of Certificate Changes (for issues 1 and above):

**Issue 1** – this Issue introduced the following changes:

1. The luminaires were re-designated as 'temporary lighting', the Description of Equipment was therefore amended accordingly, as a consequence, the warning label, 'Do not move when energised', is no longer required.
2. The anti-static coating on the end caps and bump rings was removed; in addition, optional ribs were added to the end cap.
3. A statement about independent Ingress Protection testing was introduced into the Description of Equipment.
4. The fuse rating on drawing LX-924 was corrected and is now defined as 5A, 125V.
5. An optional 'ferrite' was added to the 24 V driver.
6. Minor changes to the gear tray were recognised.
7. Plastic wire supports were added to the encapsulated LED assemblies.
8. Alternative protective ring materials were introduced.
9. An alternative potted fuse construction was recognised.
10. The introduction of alternative driver box grommets.
11. The type reference name of the silicone gasket was changed.
12. An alternative, external, non-metallic label may was allowed to be fitted.
13. The use of additional, thermal protective fuses was permitted.
14. Drawing number LX-710 was removed since the information it detailed that is relevant to explosion safety has now been included on other drawings.
15. An explanatory Condition of Certification was added to address the Intrinsic Safety marking may be applied to some of the previously certified Sockets.
16. Addition of clamp/magnet accessory.
17. Removal of ATX socket certificate number; IECEx LCI 04.0014 and replacement with IECEx LCI 07.0012U, which are the flange mounted versions.

**Issue 2** – this Issue introduced the following changes:

1. The use of the MK2 Low Voltage (LV) and MK2 High Voltage (HV) LED Driver Units was recognised; in addition, it was clarified that the devices used in the original Luminaires are referred to as the MK1 Low Voltage (LV) and MK1 High Voltage (HV) LED Driver Units.  
The MK1 LV Driver Units have a certified rating of 19 V d.c./a.c., rms to 28 V d.c./a.c., rms.  
The MK1 HV Driver Units have a certified rating of 85 V a.c. to 264 V a.c., 50/60 Hz.  
The MK2 LV Driver Units have a certified rating of 0 V to 50 V a.c./d.c.  
The MK2 HV Driver Units have a certified rating of 0 V to 264 V a.c.  
New temperature markings were introduced for Luminaires which use the MK2 Driver Units.
2. The introduction of the following design options:
  - The Ex terminal block may optionally be mounted to the chassis instead of the end cap with the associated mounting claws on the end cap optionally removed.
  - The option of including a larger bump ring on the socket fitted to the linkable versions of the product.
3. The dust marking was brought into line with the specific requirements of the compliance standards.
4. The introduction of a textile or plastic material to cover both end-caps.

**Issue 3** – this Issue introduced the following change:

1. Correction of the routine dielectric condition to allow the dc alternative test and to provide the 500 V test option for the low voltage driver.

**Issue 4** – this Issue introduced the following changes:

1. Following appropriate assessment to demonstrate compliance with the requirements of more up to date standards, IEC 60079-0:2007-10 Ed 5, IEC 60079-7:2006-07 Ed 4, IEC 60079-18:2009 Ed 3 & IEC 60079-31:2008 Ed1 were replaced by IEC 60079-0:2011-06 Ed 6, IEC 60079-7:2015-06 Ed 5, IEC 60079-18:2015 Ed 4, IEC 60079-31:2013 Ed2, the marking was amended accordingly.
2. Conduct appropriate assessment to demonstrate compliance with the requirements of IEC 60079-28:2015 Ed 2, the marking was amended accordingly.

**Date:** 04 March 2019

Page 3 of 4

**Form 9530 Issue 1**

## Sira Certification Service

Unit 6 Hawarden Industrial Park,  
Hawarden, CH5 3US, United Kingdom

Tel: +44 (0) 1244 670900  
Fax: +44 (0) 1244 681330  
Email: [ukinfo@csagroup.org](mailto:ukinfo@csagroup.org)  
Web: [www.csagroupuk.org](http://www.csagroupuk.org)

**Annexe to:** IECEx SIR 12.0070X Issue 8  
**Applicant:** Wolf Safety Lamp Company Limited  
**Apparatus:** LX-XXX LinkEx LED Luminaires



3. The use of additional resistors was permitted on the HV Mk2 variant.
4. Alternative Types of emitters (LEDs) have been permitted for equipment incorporating the Mk2 Drivers only.
5. Alternative PCB layout to accommodate linked pairs of fuses has been permitted for equipment incorporating the Mk2 Drivers only.
6. Addition of optional paint spray protection sleeve has been permitted for the Mk2 variant luminaire, resulting in a reduced maximum ambient from +55°C to +45°C, as a result two new conditions of Manufacture were added.

**Issue 5** – this Issue introduced the following changes:

1. The replacement of a diode.
2. The relocation of components for noise filtering in the thermal fuse.
3. Updated capacitor values to improve EMC.
4. Additional option for wire without 5 mm minimum bare conductor.
5. The recognition of minor drawing modifications; these amendments are administrative or involve changes to the design that do not affect the aspects of the product that are relevant to explosion safety:
  - (a) Removed Gerber reference.
  - (b) Addition of optional information for separate equipment.
  - (c) Removal of optional component.

**Issue 6** – this Issue introduced the following changes:

- 1 The product description was amended, clarifying that the LEDs are encapsulated.
- 2 The addition of an alternative RTV potting compound.
- 3 The introduction of an alternative LED heatsink assembly.
- 4 Removal of reference to 0.2mm paint spray cover thickness.
- 5 Correction of pad spacing.
- 6 Alternative positioning of D1, D3, R3 and R8.
- 7 Clarification of paint protection film and bag requirements.
- 8 Clarification of distance to metal enclosure.
- 9 Clarification of paint protection film and bag requirements temperature marking.

**Issue 7** – this Issue introduced the following change:

- 1 The introduction of the LX-XXXE Luminaire which incorporates a battery pack and is intended to provide an emergency lighting function.

**Issue 8** – this Issue introduced the following changes:

- 1
  - i. Board modifications.
  - ii. Update of certified component sockets to remove:

Manufacturer	Type	Coded	Certificate
Copper Crouse Hinds GmbH	Type GHG 51. ....R....	Ex ed [ia] IIC T6 or T5 Ex tD A21 IP66 T80°C	IECEX BKI 04.0002

And replace with:

Manufacturer	Type	Coded	Certificate
Copper Crouse Hinds GmbH	Type GHG 5118* ** * ****	Ex db eb IIC/IIB Gb Ex tb IIIC Db	IECEX BVS 15.0088U

- iii. Amendment to certificate conditions.
- iv. Administrative certificate modifications.
- v. Administrative drawing modifications.
- vi. Addition of sealant between LEDs and light pipes.
- vii. Modification to battery pack