

1 **UNITED KINGDOM CONFORMITY ASSESSMENT**  
2 **UK TYPE EXAMINATION CERTIFICATE**

3 **Product Intended for use in Potentially Explosive Atmospheres**  
4 **UKSI 2016:1107 (as amended by UKSI 2019:696) – Schedule 3A, Part 1**

5 Type Examination Certificate Number: **ExVeritas 21 UKEX 0945X** Issue: **0**

6 Product: **LBX series Luminaires**

7 Manufacturer: **Wolf Safety Lamp Company Ltd.**

8 Address: **Saxon Road Works, Sheffield, South Yorkshire, S8 0YA, United Kingdom**

9 This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

10 ExVeritas Limited Approved Body number 2585, in accordance with Regulation 42 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended by UKSI 2019:696), certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

11 Compliance with the applicable Essential Health and Safety Requirements has been assured by compliance with:

**EN IEC 60079-0: 2018                      EN 60079-18:2015+A1:2018                      EN IEC 60079-7:2015+AMD1:2017**  
**EN 60079-31:2014**

Except in respect of those requirements listed at section 16 of the schedule to this certificate.

12 If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

13 This TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Regulations apply to the manufacturing process and supply of this product. These are not covered by this certificate.

14 The marking of the equipment shall include the following:



**II 2 G Ex eb mb IIC T4 Gb**

**II 2 D Ex tb IIIC T80°C Db**

**T<sub>a</sub> -50°C to +65°C (dependent on model type)**



**No. 8613**

On behalf of ExVeritas



S Clarke CEng MSc FIET  
Managing Director

This certificate may only be reproduced in its entirety and without any change, schedule included.

The status of this certificate can be verified at [www.exveritas.com](http://www.exveritas.com)

For help or assistance relating to this certificate, contact [info@exveritas.com](mailto:info@exveritas.com).

ExVeritas, Units 16-18, Abenbury Way, Wrexham Industrial Estate, Wrexham, United Kingdom LL13 9UZ.

ExVeritas® is a registered trademark, unauthorised use will lead to prosecution.

## Schedule

### 13 Description of Equipment or Protective System

The LBX series luminaires are LED bulkhead luminaires for use in gas Group IIC and dust Group IIIC dust and gas hazardous atmospheres. The equipment comprises of a powder coated aluminium enclosure with either two or four M20 x 1.5 threaded gland entries, two at either end, and a cover with a sealed glass window. The enclosures are IP66/67 rated.

Internally, the luminaire contains LED drivers, LED modules, linear optics, and terminal blocks for

user connections. Feed through terminals are provided for ease of connection and chain linking of multiple units.

The luminaires are supplied in three distinct variants, the standard LBX\* versions contain only LED drivers, the LBX\*E versions contain LED drivers and an emergency driver and battery pack and is maintained equipment.

The LBXNE versions are non-maintained equipment which contain only the emergency system components.

The equipment is available with two supply voltage ranges and a variety of ambient ranges as detailed below:

Type	Voltage (V)	Frequency (Hz)	Current (A)	Ambient Range	Temperature Ratings
LBXNE/110	100-140	50 - 60	0.05	-40°C to +55°C	T4 & T80°C
LBXNE/230	200 - 277	50 - 60	0.02	-40°C to +55°C	T4 & T80°C
LBX1/110	88 -140	50 - 60	0.2	-50°C to +65°C	T4 & T80°C
LBX1E/110	100-140	50 - 60	0.25	-40°C to +55°C	T4 & T80°C
LBX1/230	180 - 277	50 - 60	0.1	-50°C to +65°C	T4 & T80°C
LBX1E/230	180 - 277	50 - 60	0.12	-40°C to +55°C	T4 & T80°C
LBX2/110	88 -140	50 - 60	0.35	-50°C to +50°C	T4 & T80°C
LBX2E/110	100 -140	50 - 60	0.4	-40°C to +50°C	T4 & T80°C
LBX2/230	180 - 277	50 - 60	0.15	-50°C to +50°C	T4 & T80°C
LBX2E/230	200 - 277	50 - 60	0.17	-40°C to +50°C	T4 & T80°C

### 14 Descriptive Documents

#### 14.1 Associated Report and Certificate History:

Report Number	Cert Issue Date	Issue	Comment
R3004/A/1	2021-09-09	0	Initial issue of the Prime Certificate

Certificate: **ExVeritas 21 UKEX 0945X** Issue 0

This certificate may only be reproduced in its entirety and without any change, schedule included.  
 For help or assistance relating to this certificate, contact [info@exveritas.com](mailto:info@exveritas.com).  
 ExVeritas, Units 16-18, Abenbury Way, Wrexham Industrial Estate, Wrexham, United Kingdom LL13 9UZ.  
 ExVeritas® is a registered trademark, unauthorised use will lead to prosecution.

## Schedule

### 14.2 Compliance Drawings:

#### Issue 0

Title:	Drawing No.:	Rev. Level:	Date:
LBX Lid Assembly	LD-0141	08	28/07/2021
LBX General Assembly	LD-0142	07	28/07/2021
LBX Wiring and Layout	LD-0144	08	28/07/2021
LBX Bulkhead Technical Manual (15 pages)	LD-0148	03	06/09/2021
LBX Enclosure Construction	LD-0151	08	28/07/2021
LBX Cert Label Drawing (2 pages)	LD-0159	07	19/07/2021

## 15 Conditions of Certification

### 15.1 Special Conditions for Safe Use

1. Cable entries into the equipment shall utilise suitably certified cable glands and shall provide a minimum degree of protection of IP66 or IP67 (dependent on the installation environment).
2. Unused cable entry apertures shall be closed with suitably certified blanking plugs which provide a minimum degree of protection of IP66 or IP67 (dependent on the installation environment).
3. When used in potentially hazardous dust atmospheres, the equipment shall be installed so as to minimize the risk from electrostatic discharge. In particular, the equipment shall not be installed where there is a likelihood of there being a static generating mechanism, such as steam generation or fast moving particles over the surface of the equipment.
4. The equipment shall only be used with a power source having a prospective short circuit current which does not exceed 1500A.
5. Emergency versions: The battery pack must not be replaced in or transported through a hazardous area (unless the area is shown to be non-hazardous)

Certificate: **ExVeritas 21 UKEX 0945X** Issue 0

This certificate may only be reproduced in its entirety and without any change, schedule included.  
For help or assistance relating to this certificate, contact [info@exveritas.com](mailto:info@exveritas.com).  
ExVeritas, Units 16-18, Abenbury Way, Wrexham Industrial Estate, Wrexham, United Kingdom LL13 9UZ.  
ExVeritas® is a registered trademark, unauthorised use will lead to prosecution.

## Schedule

### 15.2 Routine tests

1. Where the product incorporates certified parts or safety critical components the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.
2. The equipment shall be subjected to an electric strength test in accordance with EN 60079-7 Clause 6.1 using a test voltage of:
  - For models LBX\*/230, LBX\*/E/230 and LBXNE/230, 1554Vac applied between supply connections and frame, for a period of 60 secs
  - For models LBX\*/110, LBX\*/E/110 and LBXNE/110, 1500Vac applied between supply connections and frame, for a period of 60 secs

Alternatively, a test voltage of 20% higher may be applied for 0.1 seconds. A DC test voltage is allowed as an alternative to the AC test voltage and shall be 140% of the specified AC r.m.s. test voltage.

### 16 Essential Health and Safety Requirements (Regulations Schedule 1)

Essential Health and Safety Requirements are addressed by the standards listed in section 9 and where required the report listed in section 14.1

The manufacturer shall inform ExVeritas of any modifications to the design of the product described by this schedule.

Certificate: **ExVeritas 21 UKEX 0945X** Issue **0**

This certificate may only be reproduced in its entirety and without any change, schedule included.  
For help or assistance relating to this certificate, contact [info@exveritas.com](mailto:info@exveritas.com).  
ExVeritas, Units 16-18, Abenbury Way, Wrexham Industrial Estate, Wrexham, United Kingdom LL13 9UZ.  
ExVeritas® is a registered trademark, unauthorised use will lead to prosecution.